



Status of Implementation of M.B. Lal Committee recommendations as on April 2016

MARKETING DIVISION

Sr. No.	Item description	Total requirement (Nos.)	PO placed (Nos.)	Item installed (Nos.)	Target date for completion	Remarks (If any)
1	High volume long range monitors (HVLRL's)					
i)	500/750/1000 GPM HVLRL monitors (Remote operated)	294	294	294	31.12.2014	Recommendation complied.
ii)	1000/1500/2000 GPM HVLRL monitors (Remote operated)	38	38	38	31.12.2014	Recommendation complied.
iii)	500/750/1000GPM trolley mounted HVLRL monitors (manual)	61	61	61	31.03.2015	
iv)	1000/1500/2000 GPM Trolley mounted HVLRL monitors (manual)	27	27	27	31.05.2015	
v)	500/750/1000 GPM HVLRL monitors (manual)	18	18	18	31.12.2014	Recommendation complied.
vi)	500/750 GPM HVLRL monitors (manual)	1852	1852	1852	30.06.2015 / 30.09.2015 (siding)	
2	Automatic actuated Rim Seal Fire detection & suppression system for class "A" floating roof tanks (FRT) > 5000 kl	58	58	51	30.09.2016 (balance incomplete tanks put out of operation)	Balance nos shall be over by September 2016, however, all these tanks are out of operations (under maintenance).
3	Hydrocarbon Detection (HC) & Alarms system	367	367	367	30.11.2014	Recommendation complied.
4	Remote operated shut off valve (ROSOV)	1295	1295	1295	30.03.2016	Total 1295 ROSOVs received at various locations. 1295 no. commissioned.
5	Replacement of Hammer Blinds with double block and bleed valve (DBBV)	179	179	179	completed	Recommendation complied.



Status of Implementation of M.B. Lal Committee recommendations as on April 2016

MARKETING DIVISION

Sr. No.	Item description	Total requirement (Nos.)	PO placed (Nos.)	Item installed (Nos.)	Target date for completion	Remarks (If any)
6	Medium Expansion Foam Generators (MEFG)	356	356	356	completed	Recommendation complied.
7	Mass Flow Meters (MFM)	12	12	12	completed	Recommendation complied.
8	Emergency Kits	84 locations	84 Locations	100%	30.04.2015	Recommendation complied.
9	Closed circuit television (CCTV)	66 Locations	-	66 Locations	30.06.2015	Recommendation complied.
10	Up-gradation of fire water system - double fire contingencies	29 Locations	-	29 Locations	30.06.2014 (13 locations) 31.12.2014 (16 locations)	Recommendation complied.
11	Emergency Response Centre (ERC)	*	-	-	-	* Industry committee formed. Draft report submitted for MOP & NG for approval.
12	Training	1200 no.	1200 no.	1200 no.	31.12.2014	Recommendation complied.